

Confirmation

LEED v4.1

On 11 October 2017, Eurofins Product Testing A/S received a sample of chemical anchor with the product name:

Seal-it® 720 Chem-Fix

supplied by

Connect Products B.V.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, CDPH 01350 testing standards in the latest versions (See test report no. 392-2017-00347003_H_EN_05).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of Option 1 of LEED v4.1 BETA (July 2019): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m³ in both office and class room.

20 February 2020



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission